



NOTES

1. PIPE SHALL BE REINFORCED CONCRETE PIPE CLASS III UNLESS THE DEPTH OF PIPE REQUIRES A STRONGER CLASS.
2. ALL FITTINGS AND WYES SHALL BE MANUFACTURED AND NOT CONSTRUCTED ON THE PROJECT WITHOUT PRIOR APPROVAL FROM THE CITY ENGINEER.
3. ALL JOINTS SHALL BE WRAPPED WITH MIRAFI-140N GEOTEXTILE FABRIC OR APPROVED EQUIVALENT. EACH JOINT SHALL BE WRAPPED WITH 18" WIDE FABRIC CENTERED ON THE JOINT.



**CITY OF HUTTO**  
**CONSTRUCTION STANDARDS AND DETAILS**  
**STORM SEWER TRENCH & EMBEDMENT (PROFILE)**  
**ENGINEERING & PUBLIC WORKS**

DRAWING NO.	SD05
UPDATED:	02/01/2019
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	SD05.DWG