



NOTES:

1. CONCRETE ENCASEMENT FRO DROP CONNECTION TO BE POURED INTEGRALLY WITH BOTH MANHOLE SLAB AND WALL.
2. DROP CONNECTIONS SHALL BE REQUIRED WHENEVER AN INFLUENT SEWER IS LOCATED TWO FEET (2') OR MORE ABOVE THE MAIN INVERT CHANNEL.
3. A FLOW CHANNEL SHALL BE CONSTRUCTED INSIDE MANHOLE TO DIRECT INFLUENT INTO FLOW STREAM.
4. MINIMUM PIPE SIZE FOR DROP IS EIGHT INCHES (8").
5. SEE STANDARD MANHOLE DETAIL (WW04) FOR ADDITIONAL REQUIREMENTS.



CITY OF HUTTO
CONSTRUCTION STANDARDS AND DETAILS
DROP CONNECTION - PRECAST
MANHOLE - TYPE "A"
ENGINEERING & PUBLIC WORKS

DRAWING NO.	WW05
UPDATED:	04/01/2019
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	WW05.DWG