



**NOTES:**

1. TO BE USED WHERE DROP IS SIX INCHES (6") TO TWO FEET (2').
2. A FLOW CHANNEL SHALL BE CONSTRUCTED INSIDE MANHOLE TO DIRECT INFLUENT INTO FLOW STREAM.
3. CONSTRUCTION OF DROP SHALL PROVIDE AN OVERSIZED SLAB TO EXTEND UNDER THE DROP CONNECTION.
4. MINIMUM PIPE SIZE FOR DROP IS EIGHT INCHES (8").
5. SEE STANDARD MANHOLE DETAIL (WW04) FOR ADDITIONAL REQUIREMENTS.



**CITY OF HUTTO**  
**CONSTRUCTION STANDARDS AND DETAILS**  
**DROP CONNECTION - PRECAST**  
**MANHOLE TYPE "B"**  
**ENGINEERING & PUBLIC WORKS**

DRAWING NO.	WW05
UPDATED:	02/01/2019
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	WW05.DWG