



NOTES:

1. VALVE BOX SHALL BE AMERICAN FLOW CONTROL TRENCH ADAPTER OR CITY ENGINEER APPROVED EQUAL HAVING AN ADJUSTABLE RANGE OF + OR - SIX INCHES (6") FROM INSTALLED FINISH GRADE. (SEE VALVE SETTING CITY OF HUTTO DETAIL #W07)
2. ACCEPTABLE GATE VALVES ARE:
 - A. AMERICAN FLOW CONTROL - SERIES 2500
 - B. CLOW
 - C. KENNEDY



CITY OF HUTTO
CONSTRUCTION STANDARDS AND DETAILS
INLINE VALVE
INSTALLATION
ENGINEERING & PUBLIC WORKS

DRAWING NO.	W08
UPDATED:	04/01/2019
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	W08.DWG