


ELEVATION



PLAN

**NOTES:**

1. TRAFFIC BEARING METER BOXES WILL BE REQUIRED IN ALL PAVED AREAS AND AREAS IN WHICH MAY BE PAVED IN THE FUTURE.
2. TUBING SHALL BE CONTINUOUS FROM CORPORATION STOP TO CURB STOP, NO FITTINGS SHALL BE PERMITTED.
3. AUTOMATIC FLUSH VALVES SHALL BE USED (SEE CITY OF HUTTO DETAIL #W13). ALL AUTOMATIC FLUSH VALVES MUST BE METERED.
4. ANY VARIATIONS MUST HAVE PRIOR WRITTEN APPROVAL FROM THE CITY ENGINEER.



**CITY OF HUTTO**  
**CONSTRUCTION STANDARDS AND DETAILS**

**STANDARD**  
**BLOW-OFF**  
**ENGINEERING & PUBLIC WORKS**

DRAWING NO.	W09
UPDATED:	04/01/2019
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	W09.DWG