



*WHERE 30" MINIMUM COVER CANNOT BE OBTAINED OR DUE TO POTENTIAL SURFACE LOADING THE CIT MY REQUIRE A CAP TO BE INSTALLED.

% RETAINED **TYPICAL BEDDING SPECIFICATIONS		
SIEVE SIZE	3 / 8" F	1 / 2" D
1 / 2"	0	0
3 / 8"	0 - 2	5 - 25
4m	40 - 85	80 - 100
10m	95 - 100	95 - 100



CITY OF HUTTO
 CONSTRUCTION STANDARDS AND DETAILS
CONCRETE TRENCH
CAP
 ENGINEERING & PUBLIC WORKS

DRAWING NO.	W16
UPDATED:	01/08/2020
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	W16.DWG