


METER BOX SCHEDULE	
METER SIZE	METER BOX*
5/8"	DFW36C-KSBSM
3/4"	DFW36C-KSBSM
1"	DFW37C-KSBSM
1 1/2"	DFW65C-12-KSBSM
2"	DFW1730-18-KSBSM



NOTES:

1. ANGLE STOPS SHALL BE SIZED TO MATCH SERVICE AND METER SIZE
2. 1" ANGLE STOPS WITH 3/4" VALVES SHALL NOT BE PERMITTED
3. MULTIPLE SERVICE/METER INSTALLATIONS OR MORE THAN FOUR METERS PER SERVICE AND SERVICE LINES LARGER THAN 2" IN DIAMETER SHALL BE HANDLED ON AN INDIVIDUAL BASIS
4. 2" ANGLE STOPS SHALL BE PROVIDED WITH BOTH A LOCKING CAP AND METER FLANGE
5. BEDDING MATERIAL PER CONSTRUCTION SPECIFICATIONS
6. CASING REQUIREMENTS FOR SERVICE LINES CROSSING ROADWAYS SEE DETAIL W26
7. ANY VARIATIONS ON FITTING MUST BE APPROVED BY THE CITY ENGINEER
8. ALL SERVICE LINES SHALL BE PLACE PERPENDICULAR TO ROADWAY
9. NON-RESIDENTIAL SERVICE LINES MUST HAVE A BACKFLOW PREVENTER AT THE PROPERTY LINE ON PRIVATE PROPERTY.



CITY OF HUTTO
 CONSTRUCTION STANDARDS AND DETAILS
COMMERCIAL
WATER SERVICE
 ENGINEERING & PUBLIC WORKS

DRAWING NO.	W23
UPDATED:	04/01/2019
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	W23.DWG