



NOTES:

1. THE ENGINEER SHALL PROVIDE DESIGN ON ALL VALVES 12" AND LARGER. VALVES SHALL BE CLOW, KENNEDY, OR AMERICAN FLOW CONTROL.
2. COMPLY WITH REQUIREMENTS OF AWWA C-550, PROTECTIVE EPOXY INTERIOR COATINGS FOR VALVES.
3. CONCRETE VALVE SUPPORT, 2500 PSI CONCRETE.



CITY OF HUTTO
CONSTRUCTION STANDARDS AND DETAILS
CONCRETE VALVE
ANCHOR
ENGINEERING & PUBLIC WORKS

DRAWING NO.	W27
UPDATED:	04/01/2019
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	W27.DWG