



**\*\* TYPICAL BEDDING SPECIFICATIONS**

	$\frac{3}{8}$ " F	$\frac{1}{2}$ "
<u>SIEVE SIZE</u>	<u>% RETAINED</u>	<u>% RETAINED</u>
1/2"	0	0
3/8"	0-2	5-25
4m	40-85	80-100
10m	95-100	96-100
3/4"	-	-

NOTE:  
 IF GROUND WATER IS PRESENT IN THE TRENCH, THE BEDDING MATERIAL SHOULD BE SURROUNDED BY FILTER FABRIC (MIRAFI 140N OR EQUIVALENT) ON ALL SIDES TO PREVENT SOIL INFILTRATION INTO THE BEDDING MATERIAL.



**CITY OF HUTTO**  
 CONSTRUCTION STANDARDS AND DETAILS  
**TRENCH & EMBEDMENT**  
**UNDER NON-PAVED AREAS**  
 ENGINEERING & PUBLIC WORKS

DRAWING NO.	W22
UPDATED:	08/12/2021
DRAWN BY:	BB
SCALE:	N.T.S.
FILE NAME:	W22.DWG